



PURCHASING DEPARTMENT
P. O. Box 9534
(225) 771-4580
(225) 771-2026 (FAX)

Addendum #1

September 30, 2005

CHILD DEVELOPMENT LABORATORY

Southern University

Baton Rouge, Louisiana 70813

Bid #9899

10:00 a.m. October 13, 2005

The following modifications to the referenced project shall be incorporated into the original specifications and/or plans. Unless a change is specifically made by addendum, the specifications and/or plans as issued, shall govern. Vendors are requested to acknowledge receipt of this addendum.

- ***ATTACHED SHEETS: 1-8***
- ***Mandatory Pre-Bid List of Attendees attached***

Write in appropriate addendum number(s)

No. _____ Date _____ No. _____ Date _____
No. _____ Date _____ No. _____ Date _____

Company _____

Name _____

Evidence of Authority to submit the bids shall be in accordance with R.S. 38:2212(a)(1) and/or R.S. 39:1594©(2)(d)

Date _____

Linda A. Antoine / mjs
Linda A. Antoine-Interim Director of Purchasing

END OF ADDENDUM

ADDENDUM NO: 1

ISSUED: SEPTEMBER 26, 2005

This Addendum applicable to work designated herein shall be understood to be and is an Addendum and as such shall be part of and included in the contract.

TO ALL BIDDERS FOR FURNISHING ALL LABOR AND MATERIALS NECESSARY AND REQUIRED FOR:

CHILD DEVELOPMENT LABORATORY
Southern University and A & M College
Baton Rouge, Louisiana

CHANGES TO PROJECT MANUAL

1. BIDDING REQUIREMENTS

Front End Documents attachment prepared by Southern University and A & M College:

INSTRUCTIONS TO BIDDERS, Page 1

Add the following Paragraphs:

6. Interpretation of Documents and Prior Approvals

If any person contemplating submitting a bid desires approval of substitute materials or is in doubt as to the meaning of any part of the Drawings, specifications, of other Contract Documents, he may submit to the Architect a written request for prior approval or any interpretation no later than seven (7) days prior to the date for the opening of bids.

The person submitting the request will be responsible for its prompt delivery. Any interpretation of the proposed Documents of approval of substitute materials will be made only by addendum duly issued and a copy mailed to each holder of Drawings and Specifications no less than seventy-two (72) hours prior to the advertised time for the opening of bids excluding Saturdays, Sundays and any other legal holidays. The Owner will not be responsible for any other explanation of interpretation of the Drawings, Specifications or proposed Documents.

2. SECTION 10650- OPERABLE PARTITIONS, Page 10650-2

Paragraph 2.1.1, Acceptable Manufacturers, add the following manufacturer(s) approved as equal to those specified:

Kwik-Wall Model 2020.

CHANGES TO PROJECT DRAWINGS

3. SHEET A2 – KEY NOTES

Change Key Notes as follows:

Key Note #1 – Change ... "asphalt" ... to ... "concrete"


Key Note #10 – Change Note to read:

*New concrete driveway. New concrete driveway shall be 6" thick w/ 6x6 6/6 wire mesh reinforcing w/ 6x6 concrete curbs w/ #4 hairpins, 12" long. **Alternate Bid.***


Key Note #14 – Change Note to read:

*Existing concrete curb to be removed by Contractor. **Base Bid.***

4. DRAWING 1A2 – SITE PLAN
Change Drawing as shown:



5. DRAWING 1A2 - SITE PLAN
Change Drawing as shown:



1

**PARTIAL SITE PLAN AT NORTHEAST
CORNER OF NEW BUILDING**

Page 3 of 8

1/16"=1'-0"

6. DRAWING 3A2 – RAMP ELEVATION

Add the following Note:

NOTE: Modify existing railing at existing stair landing to accommodate new railing.

7. DRAWING 17A4 – TOILET ROOMS, Rooms 026,027, 005, 036

Change the following:


Change the water closet as shown to a tank type water closet as specified.

Add the following:

Add mirror as specified mounted over lavatory.

8. DRAWING 4A2 – RAMP SECTION

Substitute the following Drawing in lieu of the Drawing shown:



ADDED KEY NOTES

26. 18"X18" #4 REBARS, @ 24" CTR's.
27. NEW 1-1/2" GALVANIZED STEEL HANDRAIL ANCHORED TO EXISTING WALL WITH MASONRY ANCHORS.

4


RAMP SECTION

1/2"=1'-0"


9. DRAWING 2A5 – EAVE AND SOFFIT
Add the following:

Add wall insulation in the exterior wall to bottom of roof insulation.

10. DRAWING 3A5 – ENTRANCE CANOPY AT EAVE
Substitute the following Drawing in lieu of the Drawing shown:



11. DRAWING 9A5 – PROTECTIVE COVERING
Substitute the following Drawing in lieu of the Drawing shown:



9

PROTECTIVE COVERING
1/2"=1'-0"

12. SHEET P1 – PLUMBING FLOOR PLAN

Add the following Notes:

Note No. 1: New 1-1/2" water line and 4" sanitary drain line connected to existing main lin service lines on the west side of Elton C. Harrison Drive.

Note No. 3: Run new 1/2" cold water lines to all plumbing fixtures.

Note No. 3: Provide hot and cold water hose bibs and floor drain at Kitchen entrance as shown on 1A2 Site Plan and Key Note No. 15.


13. SHEET E1 – ELECTRICAL RISER DIAGRAM

Add the following Note:

Note: Existing Service Transformer at Home Economics Building is located adjacent to existing service drive, approximately 200 ft. from the new Child Development Laboratory.

14. SHEETS E1 & E2

Add Electrical Professional Engineer's Seal at bottom right corner of each sheet, as follows:



Walter R. Williamson
Electrical Engineer
Mayers & Associates, Inc
225-275-8672 / 225-291-7044

15. DRAWING E2 – FIXTURE SCHEDULE

Add the following fixtures approved as equal to those specified:

<u>Type</u>	<u>Manufacturer</u>	<u>Brand</u>	<u>Catalog Number</u>
A	Cooper Daybrite	Metalux	2GC8-232A19/156-120V-EB81-U 2TG8232-19-120-1/2EB
B	Cooper Daybrite	Metalux	2GC8-332A19/156-120V-EB81-U 2TG8332-19-120-1/3EB
C	Cooper Daybrite	Metalux	2GC8-432A19/156-120V-EB81-U 2TG8432-19-120-1/4EB
D	Cooper Daybrite	Metalux	BEU-217-120V-EB81-U WB217-CP-120-1/2EB
E	Cooper Daybrite	Metalux	WS-232A-120V-EB81-U OWN232-120-1/2EB
F	Cooper Daybrite	Metalux	CR-217A-120V-EB81-U SJ217-120-1/2EB
G	Cooper Daybrite	Fail-Safe	CTBC-PP-32A-120V CSH-32C-C-120
H	Cooper Daybrite	Port-Fluor	PD7/V1001E/7VC CM8-M100-V86
K	Cooper Daybrite	Fail-Safe	CTEC-32A-120V CSP-32C-C-120
EM	Cooper Daybrite	Sure-Lites	CC3WH VU6
X	Cooper Daybrite	Sure-Lites	LPX70RWH VERWEM

ATTENDANCE RECORD

MANDATORY PRE-BID CONFERENCE- THURSDAY, SEPTEMBER 22, 2005- 10:00 A.M.
MULTI-PURPOSE ROOM-BENJAMIN KRAFT BUILDING
SOUTHERN UNIVERSITY BATON ROUGE CAMPUS




BID NUMBER 9899

CHILD DEVELOPMENT LABORATORY

PLEASE PRINT CLEARLY IN APPROPRIATE AREAS

10/13/05

SIGN NAME

COMPANY	REPRESENTATIVE	ADDRESS	TELEPHONE NO.	FAX NO.	SIGN-OUT
CHARLES CARVER CONST.	RECHIE NAQUIN	1565 CHOCTAW BLVD, B. R., LA. 70805	337-9698	337-9604	
Cord Development Corp	Maggie Achord	1827 Hwy 68 Jackson, La. 70748	654-3033	654-9496	Maggie Achord
Nottingham Construction	TOO SHARR	13073 Plank Ro. Baton, LA 70714	774-4273	774-4354	
Mount General Contractors, LLC	Steve Melin	P.O. Box 1090 Walker, La. 70785	664-3520	664-6872	Steve Melin
Mount General Contractors, LLC Southern Uni, FAC, PL.	Mary L. Wells	811 Pace Pl.	771-3671	771-2922	Mary L. Wells
SAA SHORT & ASSOCIATES	SAA SHORT & ASSOCIATES	143 LEE PL SUITE 202, N. 70808	769-1152	same	

ATTENDANCE RECORD

MANDATORY PRE-BID CONFERENCE- THURSDAY, SEPTEMBER 22, 2005- 10:00 A.M.
MULTI-PURPOSE ROOM-BENJAMIN KRAFT BUILDING
SOUTHERN UNIVERSITY BATON ROUGE CAMPUS

BID NUMBER 9899 CHILD DEVELOPMENT LABORATORY

PLEASE PRINT CLEARLY IN APPROPRIATE AREAS

10/13/05

SIGN NAME

COMPANY	REPRESENTATIVE	ADDRESS	TELEPHONE NO.	FAX NO.	SIGN-OUT
SU HARR DENIER	James Hancock	Southern University 11015 Perkins road Baton Rouge, LA 70810	771-2272	771-2841	James Hancock
J. Reed Erectors	Matthew Braussard	70815 Baton Rouge, LA 70810	763-6920	763-6950	Matthew Braussard
B.M.D. Const	Doune LeCombe	70815 8305 Tom Ave B241	928-5569	927-2212	Doune LeCombe
EDGEMERL const	DONALD EDGEMERL	70810 1414 NICHOLAND RD	363-4265	363-4766	Donald Edgemerl
Bayou Bush Const Co	Bayou Bush	po box 14649 Bk 70898	766-9284	769-0506	Bayou Bush
A.U. Purchasing	Mary Jane Sproule	PO B 9534 B.E., La. 70813	771-4580	771-3026	Mary Jane Sproule

ATTENDANCE RECORD


MANDATORY PRE-BID CONFERENCE- THURSDAY, SEPTEMBER 22, 2005- 10:00 A.M.
MULTI-PURPOSE ROOM- BENJAMIN KRAFT BUILDING
SOUTHERN UNIVERSITY BATON ROUGE CAMPUS

BID NUMBER 9899 CHILD DEVELOPMENT LABORATORY

PLEASE PRINT CLEARLY IN APPROPRIATE AREAS

10/13/05

SIGN NAME

COMPANY	REPRESENTATIVE	ADDRESS	TELEPHONE NO.	FAX NO.	SIGN-OUT
MATRIX Cons. Co, Inc	BOB WILBURN	10630 OLD LODGE CT. B.A., LA. 70817	752-8675	756-9781	
Sgt Arnold CHFCs	Dennis Jones	Callego & As. P+LS Spartanburg, SC Baton Rouge LA 70813	771-3660	771 5134	